


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR
ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE


| | |
|--|--|
| Product | Moulded case circuit-breakers |
| Name and address of the applicant | Zhejiang Chint Electrics Co., Ltd. No.1, Chint Road, Chint Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, 325603, P.R. CHINA |
| Name and address of the manufacturer | Same as applicant |
| Name and address of the factory Note: When more than one factory, please report on page 2 | Same as applicant |
| Ratings and principal characteristics | Ue= 240V~(1P), 415V~(2, 3, 4P), 50/60Hz, In= 63, 80, 100, 125A; Cat. A, Ui= 500V, DZ158-125H: Icu= 10000A, Ics= 7500A, DZ158-125: Icu= Ics= 6000A |
| Trademark (if any) |  |
| Customer's Testing Facility (CTF) Stage used | - |
| Model / Type Ref. | DZ158-125H, DZ158-125 |
| Additional information (if necessary may also be reported on page 2) | - |
| A sample of the product was tested and found to be in conformity with | IEC 60947-2:2016 |
| As shown in the Test Report Ref. No. which forms part of this Certificate | 170100608SHA-001, 170100608SHA-002, 170100608SHA-003, 170100608SHA-004 |

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 4 July 2017



Signature: 

Leif Söderlund