

**IEC****IECEE**  
CB  
SCHEME

Ref. Certif. No.

**SE-46495**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC**CB TEST CERTIFICATE****CERTIFICAT D'ESSAI OC**Product  
Produit

Contactor for household and similar purposes

Name and address of the applicant  
Nom et adresse du demandeurZhejiang Chint Electrics Co., Ltd., Chint High-tech Industrial Zone,  
North Baixiang 325603, Wenzhou, Zhejiang, CHINAName and address of the manufacturer  
Nom et adresse du fabricant

Same as applicant

Name and address of the factory  
Nom et adresse de l'usine

Same as applicant

Ratings and principal characteristics  
Valeurs nominales et caractéristiques principalesU<sub>e</sub>= 230V~ (2-Pole)  
I<sub>th</sub>= 20A, I<sub>e</sub>= 20A (AC-7a); I<sub>e</sub>= 9A (AC-7b)  
U<sub>i</sub>= 500V~, U<sub>s</sub>= 220/230V~, I<sub>r</sub>= 3000A, I<sub>q</sub>= 6000ATrademark (if any)  
Marque de fabrique (si elle existe)**CHNT**Model / Type Ref.  
Ref. De type

NCH8-20

Additional information (if necessary)  
Les informations complémentaires (si nécessaire)A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à la

IEC 61095:1992 and A1


As shown in the Test Report Ref. No. which forms part  
of this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

607539-1

This CB Test Certificate is issued by the National Certification Body  
Ce Certificat d'essai OC est établi par l'Organisme **National de Certification**Intertek Semko AB  
Box 1103  
SE-164 22 Kista, Sweden  
Int +46 8 750 00 00**Intertek ETL SEMKO**

Date: 10 August 2006

Signature:



sve/ku

Intertek Testing Services Ltd, Shanghai, ETL SEMKO  
Building No. 86  
1198 Qinzhou Road (North)  
Caohejing Development Zone  
Shanghai 200233  
KINA

Handled by  
Roger Larson  
Direct telephone  
+46 8 750 01 32  
Reference  
607539  
E-mail  
roger.larson@intertek.com  
Your Reference  
JSH006050762 / Joyce Xu

10 August 2006

**Intertek S Mark Certificate with No. 607539**

We are pleased to enclose the Intertek S Mark Certificate you have applied for.

**The S Mark – a marketing resource**

S Mark Certification is a way of making sure that your brand's equity will not be put at risk by a safety failure of the product. The use of the S Mark in your marketing is also a way of adding value to your brand and promoting trust among your customers.

The S Mark is a European safety mark offered by Intertek ETL SEMKO. The letter 'S' tells 450 million people in Europe that your product is safe. The word for safety starts with an 'S' in most of the languages in Europe, e.g. Safety, Sicherheit, Seguridad, Sécurité, Sicurezza, and Säkerhet.

As products become increasingly interchangeable, trust counts more than ever. This is why the S Mark is a key selling point. It is a well known symbol for safety and shows that Intertek has independently tested and certified the product's compliance to applicable European safety requirements. Critical consumers and retailers look for third-party validation to complement their CE marking, as it helps retailers to meet their product liability requirements, and make the consumers' buying process simpler.



Read more about the S Mark and how other companies use it to gain competitive advantage: [www.etlsemko.com/s-mark](http://www.etlsemko.com/s-mark)

**Mandatory factory inspections**

In addition to your product certification, it is mandatory for inspections to be performed at your manufacturing site/s. The inspections are carried out by our inspectors or subcontractors. For details of the technical requirements for these inspections, please contact [inspection.etlsemko@intertek.com](mailto:inspection.etlsemko@intertek.com).

Yours sincerely

Intertek Semko AB  
Certification

Enclosure: Intertek S Mark Certificate



*Handwritten signature*

Intertek Semko AB

Torshamnsgatan 43, Box 1103, SE-164 22 Kista, Sweden

Telephone +46 8 750 00 00, Fax +46 8 750 60 30, [www.sweden.intertek-etlsemko.com](http://www.sweden.intertek-etlsemko.com)

Registered in Sweden: No SE556024059901, Registered office: As address

*BSE*

1(1)

Zhejiang Chint Electrics Co., Ltd.  
Chint High-tech Industrial Zone  
North Baixiang 325603  
Wenzhou, Zhejiang  
KINA

Handled by  
Roger Larson  
Direct telephone  
+46 8 750 01 32  
Reference  
607539  
E-mail  
roger.larson@intertek.com  
Your reference

10 August 2006

**CB-Application(s) SE-46495**

We have the pleasure to enclose a (the) requested CB-certificate(s) and the pertaining Test Report.

We also enclose a form for Identity Declaration (ID). The ID shall be filled in by you and be used to verify that the specimen to be submitted to other Certification Bodies is absolutely identical with the one we have tested. On the basis of these documents you may apply for a licence to use the national marks of the countries whose Certification Bodies have signed the agreement. The documents together with a specimen should be submitted in the country where approval is applied for and in accordance with the relevant national procedures.

Yours sincerely

Intertek Semko AB  
Product Certification

**Enclosure CB certificate(s)**



Intertek Semko AB

Torshamnsgatan 43, Box 1103, SE-164 22 Kista, Sweden  
Telephone +46 8 750 00 00, Fax +46 8 750 60 30, www.sweden.intertek-etlsemko.com  
Registered in Sweden: No SE556024059901, Registered office: As address

1(1)

# IDENTITY DECLARATION

To

To be issued by the manufacturer

\_\_\_\_\_  
Certification Body, Name and Address

We declare that the electrical product

\_\_\_\_\_  
type designation \_\_\_\_\_

for which we apply for the licence to use your mark of conformity is identical in all respects (e.g. design, construction, properties, components) to the tested specimen for which the CB Certificate

No \_\_\_\_\_ Date \_\_\_\_\_

was issued by


\_\_\_\_\_  
Place / Date \_\_\_\_\_ Company \_\_\_\_\_

\_\_\_\_\_  
Legally binding signature of the manufacturer

## TEST REPORT

## IEC 61095

## Electromechanical contactors for household and similar purposes

<b>Report reference No</b> .....	607539-1
Tested by (printed name and signature) .....	Erik Lundell 
Approved by (printed name and signature) .....	Bo Erlandsson 
Date of issue .....	2006-08-10
<b>CB/CCA Testing Laboratory</b> .....	Intertek SEMKO AB
Address .....	Thorshamnsgatan 43 Box 1103, SE-164 22 Kista SWEDEN
Testing location/ procedure .....	TL <input type="checkbox"/> RMT <input type="checkbox"/> SMT <input type="checkbox"/> WMT <input type="checkbox"/> TMP <input checked="" type="checkbox"/>
Testing location/ address .....	Chint High-tech Industrial Zone, North Baixiang 325603, Wenzhou, Zhejiang, P.R.China
<b>Applicant's name</b> .....	Zhejiang Chint Electrics Co., Ltd.
Address .....	Chint High-tech Industrial Zone, North Baixiang 325603, Wenzhou, Zhejiang, P.R.China
<b>Test specification</b>	
Standard .....	IEC 61095:2000 / Edition 1.1 EN 61095:1993 + A11:1996 + A1:2000
Test procedure .....	CB / CCA
Procedure deviation .....	N/A
Non-standard test method .....	N/A
<b>Test Report Form</b>	
Test Report Form No. ....	IEC61095A
TRF originator .....	EZU
Master TRF .....	dated 01-12
Copyright reserved to the bodies participating in the IECEE Schemes (CB and CB-FCS) and/or the bodies participating in the C.I.G (CCA-ENEC).	
This publication may be reproduced in whole or in part for non-commercial purposes as long as the IECEE is acknowledged as copyright owner and source of the material. IECEE takes no responsibility for and will not assume liability for damages resulting from the reader's interpretation of the reproduced material due to its placement and context.	
Test item description .....	AC contactor
Trademark .....	<b>CHNT</b>
Model / type reference .....	NCH8-20
Manufacturer .....	Same as applicant
Rating(s) .....	U <sub>e</sub> = 230V~ I <sub>e</sub> = 20A (AC-7a), I <sub>e</sub> = 9A (AC-7b)

TRF No.: IEC61095A

Intertek Semko AB

Torshamnsgatan 43, Box 1103, SE-164 22 Kista, Sweden

Telephone +46 8 750 00 00, Fax +46 8 750 60 30, www.sweden.intertek-etlsemko.com

Registered in Sweden: No SE556024059901, Registered office: As address

TRF originator: EZU



## Test items particulars :

- number of poles ..... : 2
- method of control ..... : **Automatic** / non-automatic / semi-automatic

## Rated and limiting values for main circuits :

- rated operational voltage  $U_e$  (V)..... : 230V~
- rated insulation voltage  $U_i$  (V)..... : 500V~
- rated impulse withstand voltage  $U_{imp}$  (V) ... : N/A
- conventional free air thermal current  $I_{th}$  (A) : 20A
- conventional enclosed thermal current  $I_{the}$  (A) ..... : N/A
- rated operational currents  $I_e$  (A) or rated operational powers..... : 20A (AC-7a), 9A (AC-7b)
- rated frequency (Hz) ..... : 50/60Hz

## Normal load and overload characteristics..... :

- ability to withstand motor switching overload currents ..... : N/A
- rated making capacity..... : See utilization category
- rated breaking capacity..... : See utilization category
- conventional operational performance..... : See utilization category

Rated conditional short-circuit current ..... :  $I_r=3000A$ ,  $I_q=6000A$ 

Utilization category ..... : AC-7a / AC-7b

## Control circuits:

- kind of current..... : AC
- rated frequency..... : 50/60Hz
- rated control circuit voltage  $U_c$  ..... : N/A
- rated control supply voltage  $U_s$ ..... : 220/230V~
- suitability to be connected to SELV circuits : N/A

Auxiliary circuits ..... : N/A

Pollution degree ..... : Pollution degree 1 / 2 / 3 / 4

## Test case verdicts

- Test case does not apply to the test object ... : N/A
- Test item does meet the requirement ..... : P(ass)
- Test item does not meet the requirement ..... : Testing

## Testing

Date of receipt of test item ..... : May 29, 2006

Date(s) of performance of test ..... : From May 30, 2006 to July 10, 2006

## General remarks :

**This report is not valid as a CB Test Report unless signed by an approved CB Testing Laboratory and appended to a CB Test Certificate issued by an NCB in accordance with IEC60060-2.**

This report shall not be reproduced except in full without the written approval of the testing laboratory.



The test results presented in this report relate only to the item(s) tested.

"(see remark #)" refers to a remark appended to the report.

"(see Annex #)" refers to an annex appended to the report.

Throughout this report a comma is used as the decimal separator.

Copy of marking plate and summary of testing (information/comments):





IEC 61095			
Cl.	Requirement – Test	Result	Verdict
6	PRODUCT INFORMATION		
6.1.1	Identification:		
	- a) manufacturer's name or trade mark .....	<b>CHNT</b>	P
	- b) type designation or serial number .....	NCH8-20	P
	- c) number of this standard (on nameplate) .....	IEC 61095	P
6.1.2	Characteristics, basic rated values and utilization		
	- d) rated operational voltages .....	230V~	P
	- e) utilization category and rated operational currents (or rated powers), at the rated operational voltage .....	AC-7a/AC-7b	P
	- f) rated frequency .....	50/60Hz	P
	- g) rated duty with indication of the class of intermittent duty .....	Continuous duty; Intermittent duty: class 30	P
	Associated values:		
	- h) rated making and breaking capacities .....	See item e)	P
	Safety and installation:		
	- i) rated insulation voltage .....	500V~	P
	- j) rated impulse withstand voltage .....		N/A
	- k) IP code (on enclosure) .....		N/A
	- l) pollution degree .....	2	P
	- m) rated conditional short-circuit current and type, current rating and characteristics of the associated SCPD .....	I <sub>r</sub> =3000A, I <sub>q</sub> =6000A, CBO: NB1-63, C32	P
	- n) switching overvoltages .....	≤1200V	P
	Control circuits: (on the coil or on the contactor)		
	- o) rated control circuit voltage (U <sub>c</sub> ), nature of current and rated frequency .....		N/A
	- p) nature of current, rated frequency and rated control supply voltage (U <sub>s</sub> ) .....	220/230V~	P
	For contactors with control circuit for a SELV supply:		
	- q) suitability of the control circuit to be connected to a SELV supply .....		N/A
	Auxiliary circuits:		
	- r) ratings of auxiliary circuits .....		N/A
6.2	Marking		
	Markings are indelible and easily legible		P
	Markings on contactor, preferably on nameplate:		
	- manufacturer's name or trade mark .....	<b>CHNT</b>	P
	- type designation or serial number .....	NCH8-20	P

IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	Following information (marked and visible after mounting):		
	- direction of movement of the actuator..... :		N/A
	- indication of the position of the actuator..... :		N/A
	- approval or certification mark (on nameplate) .. :		P
	- symbol, colour code or letter code ..... : (for miniaturized contactors)		N/A
	- terminal identification and marking ..... :	A wiring diagram is provided on the product surface and marked with "R1/R2/R3/R4 A1/A2"	P
	- IP code and class of protection against electric shock..... :		N/A
	Markings not on screw or removable parts		P
	Data under d) to j) and l) to r) on nameplate, or on contactor, or in manufacture's published literature		P
	Marking of terminals in accordance with annex A of this standard		P

8	CONSTRUCTIONAL AND PERFORMANCE REQUIREMENTS		
8.1.1	Materials		
8.1.2	Strength of screws or nuts other than those on terminals which are intended to be operated during installation or maintenance		P
8.1.3	Clearances and creepage distances		
	a) Uimp is declared		
	Rated impulse withstand voltage Uimp (V) .....	Not declared	
	minimum clearances (mm)..... :		
	measured clearances (mm) .....		N/A
	minimum creepage distances (mm)..... :		
	measured creepage distances (mm) .....		N/A
	b) Uimp is not declared (see table 2)		
	1. clearances (mm) .....	3mm <i>Between live parts of difference polarity</i>	
	measured clearances (mm) .....	3,8mm	P
	2. minimum clearances (mm)..... :	3(6)mm <i>Between live parts and exposed conductive parts</i>	
	measured clearances (mm) .....	No exposed conductive parts	N/A
	1. minimum creepage distances (mm)..... :	3mm <i>between live parts which are separated when the contactor is in the open position</i>	
	measured creepage distances (mm) .....	7,2mm	P

IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	2. minimum creepage distances (mm)..... :	3mm <i>between live parts of different polarity</i>	
	measured creepage distances (mm) .....	7,2mm	P
	3. minimum creepage distances (mm)..... :	3(6)mm <i>Between live parts and exposed conductive parts</i>	
	measured creepage distances (mm) .....	No exposed conductive parts	N/A
8.1.4	Actuator (for manually operated actuator)		
	Insulation		N/A
	Direction of movement (comply with IEC 60447:74)		N/A
	Mounting		N/A
8.1.5	Indication of the OFF and ON positions		
	Indicating means	By a mechanical indicator	P
	if symbols are used, comply with IEC 60417..... :		N/A
	Only push-button to open circuit is red or marked "O" .....		N/A
	Colours push-buttons, illuminated push-buttons and indicator lights comply with IEC 73		N/A
	Indication by the actuator		N/A
8.1.6	Terminals		
	All parts of terminals which maintain contact and carry current shall be of metal having adequate mechanical strength		P
	Terminal connections shall be such that necessary contact pressure is maintained		P
	Terminals shall be so constructed that the conductor is clamped between suitable surfaces without damage to the conductor and terminal		P
	Terminals shall not allow the conductors to be displaced, or be displaced themselves in a manner detrimental to the operation of the contactor and the insulation voltage shall not be reduced below the rated values		P
	Connecting capacity		
	type of conductors .....	Rigid-solid or rigid-stranded	
	minimum cross-sections of conductors (mm <sup>2</sup> ).... :	1,5 mm <sup>2</sup>	
	maximum cross-sections of conductors (mm <sup>2</sup> )... :	4 mm <sup>2</sup>	
	number of conductors simultaneously connectable to the terminal .....	1	
	Connection		
	Terminals for connection to external conductors shall be readily accessible during installation		P

IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	Clamping screws and nuts shall not serve to fix any other component		P
	Terminal identification and marking		
	terminals clearly and permanently identified (comply with IEC 60445) .....	R1/R2/R3/R4 A1/A2	P
	terminal intended exclusively for the neutral conductor: N .....		N/A
	protective earth terminal: symbol.....		N/A
8.1.7	Additional requirements for contactors provided with a neutral pole		
	pole intended only for connecting the neutral terminal: N.....		N/A
	the switched neutral pole not break before and not make after the other poles .....		N/A
	conventional thermal current.....		N/A
8.1.8	Provisions for earthing		
	Constructional requirements		N/A
	the exposed conductive parts shall be electrically intrerconnected and connected to a protective earth terminal		N/A
	Protective earth terminal		N/A
	the protective earth terminal shall be readily accessible		N/A
	the protective earth terminal shall be suitably protected against corrosion		N/A
	the protective earth terminal have no other function (except PEN)		N/A
	Protective earth terminal marking and identification		
	protective earth terminal is clearly and permanently identified .....		N/A
8.1.9	Enclosures		
	Design		
	the enclosure, when it is opened: all parts requiring access for installation and maintenance are readily accessible		N/A
	sufficient space shall be provided inside the enclosure		N/A
	the fixed parts of a metal enclosure are electrically connected to the other exposed conductive parts and connected to a terminal which enables them to be earthed		N/A
	removable metal parts of the enclosure are not insulated from the part carrying the earth terminal		N/A

IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	removable parts of the enclosure are firmly secured to the fixed parts by a device		N/A
	for enclosures having a degree of protection IP 1X up to and including IP 4X, sufficient space be provided for establishing a drain-hole (comply with IEC 60947-1)		N/A
	Enclosures have adequate mechanical strength		N/A
	no possible to remove any cover of the enclosure without the use of a tool		N/A
	if the enclosure is used for mounting push-buttons, it shall not be possible to remove the buttons from the outside of the enclosure		N/A
	Insulation		N/A
	if the enclosure is partly or completely lined with insulating material, then this lining is securely fixed to the enclosure		N/A
8.1.10	Degrees of protection of enclosed contactors		
	degree of protection ..... : IP20 to front parts		P
8.3	Electromagnetic compatibility		
	Immunity: no tests are required		P
	Emission: no tests are required		P

	TEST SEQUENCE A:			
	3 samples: $I_{th}=20A$ , $I_e=20A$ , AC-7a	A1	A2	A3
9.3.3.3	Temperature-rise limits			
	ambient air temperature 10-40°C..... : 23°C			
	test enclosure W x H x D (mm x mm x mm)..... : Not applied			
	material of enclosure..... : Not applied			
	Main circuit, test conditions:			
	conventional free air thermal current $I_{th}$ (A)..... : 20A			
	conventional enclosed thermal current $I_{the}$ (A).. : Not applied			
	cross-section of conductors ( $mm^2$ )..... : 2,5 $mm^2$			
	temperature-rise:	[K]	[K]	[K]
	Terminal (65K) ..... : 40	37	44	P
	Parts intended to be touched but not hand-held: non-metallic (40K) ..... : 12	15	10	P
	Control circuits:			
	temperature-rise:	[K]	[K]	[K]
	Terminal (65K) ..... : 15	16	13	P
	Coils of electromagnets (Class B: $\leq 110K$ )			
	temperature rise ..... : [K]	[K]	[K]	

IEC 61095					
Cl.	Requirement – Test	Result			Verdict
	-eight-hour duty (continuous duty) windings..... :	44	41	42	P
	-intermittent duty windings..... :	40	38	40	P
	Auxiliary circuits				
	temperature rise	Not applied			N/A
9.3.3.2	Operation and operating limits				
	rated control supply voltage $U_s$ (V) .....	220/230V			
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage $U_s$ :	187V~253V			P
	limits of drop out and open fully are: 75% to 20% of rated control supply voltage $U_s$ ... :	58V	64V	69V	P
	Limits for closing are applicable with the coil circuit resistance at +40°C .....				P
	Limits for drop-out are applicable with the coil circuit resistance at -5°C .....				P
9.3.3.5	Rated making and breaking capacities				
	utilization category .....	AC-7a			
	rated operational voltage $U_e$ (V) .....	230V			
	rated operational current $I_e$ (A) or power (kW) ... :	20A			
	Conditions, make/break operations:				
	- test voltage $U/U_e = 1,05$ (V)..... :	L1: 242V L2: 242V L3: -			P
	- test current $I/I_e = 1,5$ (A) .....	L1: 30A L2: 30A L3: -			P
	- power factor .....	L1: 0,8 L2: 0,8 L3: -			P
	- on-time (ms)..... :	50ms			P
	- off-time (s)..... :	10s			P
	- number of make/break cycles .....	50			P
	Behaviour and condition during and after the test:				
	- no permanent arcing				P
	- no flash-over between poles				P
	- no blowing of the fusible element in the earth circuit				P
	- no welding of the contacts				P
	Dielectric test:				
	test voltage (2 $U_e$ , minimum of 1000 V) for 1 min:	1000V~			

IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	No flashover or breakdown		P
	Characteristics of transient recovery voltage		
	only for category AC-7b		N/A
	Switching overvoltages		N/A

TEST SEQUENCE A:					
3 samples: $I_{th}=20A$ , $I_e=9A$ , AC-7b					
	A4	A5	A6		
9.3.3.3	Temperature-rise limits				
	ambient air temperature 10-40°C..... :			23°C	
	test enclosure W x H x D (mm x mm x mm)..... :			Not applied	
	material of enclosure..... :			Not applied	
	Main circuit, test conditions:				
	conventional free air thermal current $I_{th}$ (A)..... :			20A	
	conventional enclosed thermal current $I_{the}$ (A)..... :			Not applied	
	cross-section of conductors (mm <sup>2</sup> )..... :			2,5 mm <sup>2</sup>	
	temperature-rise:			[K] [K] [K]	
	Terminal (65K) .....	38	39	43	P
	Parts intended to be touched but not hand-held: non-metallic (40K) .....	11	11	13	P
	Control circuits:				
	temperature-rise:			[K] [K] [K]	
	Terminal (65K) .....	14	16	17	P
	Coils of electromagnets (Class B: $\leq 110K$ )				
	temperature rise .....			[K] [K] [K]	
	-eight-hour duty (continuous duty) windings..... :	41	38	40	P
	-intermittent duty windings..... :	37	36	35	P
	Auxiliary circuits				
	temperature rise			Not applied	N/A
9.3.3.2	Operation and operating limits				
	rated control supply voltage $U_s$ (V) .....			220/230V	
	limits of close satisfactorily at any value between 85% and 110% of rated control supply voltage $U_s$ :			187V~253V	P
	limits of drop out and open fully are: 75% to 20% of rated control supply voltage $U_s$ ... :			68V 75V 65V	P
	Limits for closing are applicable with the coil circuit resistance at +40°C .....				P
	Limits for drop-out are applicable with the coil circuit resistance at -5°C .....				P

IEC 61095			
Cl.	Requirement – Test	Result	Verdict
9.3.3.5	Rated making and breaking capacities		
	utilization category .....	AC-7b	
	rated operational voltage $U_e$ (V) .....	230V	
	rated operational current $I_e$ (A) or power (kW) ...	9A	
	Conditions, make/break operations:		
	- test voltage $U/U_e = 1,05$ (V).....	L1: 242V L2: 242V L3: -	P
	- test current $I/I_e = 8$ (A) .....	L1: 72,4A L2: 72,4A L3: -	P
	- power factor .....	L1: 0,45 L2: 0,45 L3: -	P
	- on-time (ms).....	50ms	P
	- off-time (s).....	10s	P
	- number of make/break cycles .....	50	P
	Behaviour and condition during and after the test:		
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	Dielectric test:		
	test voltage ( $2 U_e$ , minimum of 1000 V) for 1 min:	1000V~	
	No flashover or breakdown		P
	Characteristics of transient recovery voltage		
	only for category AC-7b		P
	Switching overvoltages	960V	P

	TEST SEQUENCE B			
	3 samples: $I_{th} = 20A$ , $I_e = 20A$ , AC-7a	B1	B2	B3
9.3.3.4	Dielectric properties			
	a) Test of dielectric properties, rated impulse withstand voltage ( $U_{imp}$ ) declared:			N/A
9.3.3.4.1	- rated impulse withstand voltage (V) .....			
	- test $U_{imp}$ (V) (table 16).....	4 kV		P
	b) Test of dielectric properties, rated impulse withstand voltage ( $U_{imp}$ ) not declared			P
9.3.3.4.2	- rated insulation voltage $U_i$ (V) .....	500V		



IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	value of test voltage:		
	- a) for the main circuit and for control and auxiliary circuits ( are not covered by paragraph b ) .....	1000 / 2000 / 2500 V a.c.	P
	- b) for control circuits and auxiliary circuits (unsuitable for connection to the main circuit).....	1000V / 2Ui+1000 V (2000V)	P
	- c) for contactors to be used in SELV (between live parts of safety extra-low voltage circuits and any other circuit).....	4000 V	N/A
	no disruptive discharge		P
9.3.3.6	Conventional operational performance		
	utilization category .....	AC-7a	
	rated operational voltage Ue (V) .....	230V	
	rated operational current Ie (A) or power (kW) ...	20A	
	Conditions, make/break operations or <b>make operation</b> AC-7a:		
	- test voltage U/Ue= 1,05 (V).....	L1: 242V L2: 242V L3: -	P
	- test current I/Ie= 1,0 (A) .....	L1: 20A L2: 20A L3: -	P
	- power factor .....	L1: 0,8 L2: 0,8 L3: -	P
	Conditions, break operation AC-7a:		
	- test voltage U/Ue = 1,05 (V).....	L1: 242V L2: 242V L3: -	P
	- test current I/Ie (A) = 1,0 (A) .....	L1: 20A L2: 20A L3: -	P
	- power factor .....	L1: 0,79 L2: 0,79 L3: -	P
	- on-time (ms).....	50ms	P
	- off-time (s).....	10s	P
	- number of make/break cycles .....	30000	P
	Behaviour and condition during and after the test:		
	- no permanent arcing		P

IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	Dielectric test:		
	test voltage (2 U <sub>e</sub> , minimum of 1000 V) for 1 min:	1000V~	
	No flashover or breakdown		P

	TEST SEQUENCE B			
	3 samples: I <sub>th</sub> =20A, I <sub>e</sub> =9A, AC-7b	B4	B5	B6
9.3.3.4	Dielectric properties			
	a) Test of dielectric properties, rated impulse withstand voltage (U <sub>imp</sub> ) declared:			N/A
9.3.3.4.1	- rated impulse withstand voltage (V)..... :			
	- test U <sub>imp</sub> (V) (table 16)..... :	4kV		P
	b) Test of dielectric properties, rated impulse withstand voltage (U <sub>imp</sub> ) not declared			P
9.3.3.4.2	- rated insulation voltage U <sub>i</sub> (V)..... :	500V		
	value of test voltage:			
	- a) for the main circuit and for control and auxiliary circuits ( are not covered by paragraph b )..... :	1000 / 2000 / 2500 V a.c.		P
	- b) for control circuits and auxiliary circuits (unsuitable for connection to the main circuit)..... :	1000V / 2U <sub>i</sub> +1000 V (2000V)		P
	- c) for contactors to be used in SELV (between live parts of safety extra-low voltage circuits and any other circuit)..... :	4000V		N/A
	no disruptive discharge			P
9.3.3.6	Conventional operational performance			
	utilization category..... :	AC-7b		
	rated operational voltage U <sub>e</sub> (V) .....	230V		
	rated operational current I <sub>e</sub> (A) or power (kW) ... :	9A		
	Conditions, make/break operations or <b>make operation</b> AC-7b:			
	- test voltage U/U <sub>e</sub> = 1,0 (V)..... :	L1: 230V L2: 230V L3: -		P
	- test current I/I <sub>e</sub> = 6,0 (A) .....	L1: 56,1A L2: 56,1A L3: -		P

## IEC 61095

Cl.	Requirement – Test	Result	Verdict
	- power factor .....	L1: 0,42 L2: 0,42 L3: -	P
	Conditions, break operation AC-7b:		
	- test voltage $U/U_e = 0,17$ (V).....	L1: 39V L2: 39V L3: -	P
	- test current $I/I_e$ (A) = 1,0 (A) .....	L1: 9,4A L2: 9,4A L3: -	P
	- power factor .....	L1: 0,42 L2: 0,42 L3: -	P
	- on-time (ms).....	50ms	P
	- off-time (s).....	10s	P
	- number of make/break cycles .....	30000	P
	Behaviour and condition during and after the test:		
	- no permanent arcing		P
	- no flash-over between poles		P
	- no blowing of the fusible element in the earth circuit		P
	- no welding of the contacts		P
	Dielectric test:		
	test voltage (2 $U_e$ , minimum of 1000 V) for 1 min:	1000V~	
	No flashover or breakdown		P

	TEST SEQUENCE C 1 sample: $I_{th} = 20A$ , $I_e = 9A$ , AC-7b		C1	
9.2.1.2	Resistance to humidity			
	test Ca: damp heat (IEC 60068-2-3) .....	4 days		P
	test voltage (2 $U_e$ , minimum of 1000 V) for 1 min:	1000V~		
	No flashover or breakdown			P
9.3.5	Ability to withstand overload currents (only for utilization category AC-7b)			
	test current (8 x $I_e$ max) (A) .....	72,4A		
	duration of test.....	10 s		
	After test contactor in the same condition			P
9.2.1.5	Resistance to rusting			

IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	10 min in a 10% solution of ammonium chloride; 10 min in humid ambient; 10 min in heating cabinet at a temperature of 100°C .....		
	No signs of rust		P

	TEST SEQUENCE D 1 sample: $I_{th}=20A$ , $I_e=9A$ , AC-7b		D1	
9.2.6	Durability of marking			
	Marking durable and easily legible: 15 s water; 15 s petroleum spirit	Marking made by printing		P
9.2.5	Resistance to impact			
9.2.5.2.1	Pendulum hammer test (unenclosed contactors, exposed parts and partially enclosed contactors, covers and cover plates)			P
	10 blows with a shock energy of 0,5 J			P
	After the test, no damage; live parts not accessible			P
9.2.5.2.2	Sphere test (enclosures for contactors)			
	10 blows with a shock energy of 2 J (figure 9)			N/A
	After the test , no damage; live parts not accessible			N/A
9.3.3.4	Verification of clearances when necessary and verification of creepage distances			
	rated impulse withstand voltage $U_{imp}$ (V).....:	Not declare but tested acc. to 4kV		
	1. minimum clearances (mm) (table 17) .....	3mm <i>Between live parts of difference polarity</i>		
	measured clearances (mm) .....	3,8mm		P
	2. minimum clearances (mm) (table 17) .....	3mm <i>Between live parts and exposed conductive parts</i>		
	measured clearances (mm) .....	No exposed conductive parts		N/A
	rated insulation voltage $U_i$ (V) .....	500V		
	1. minimum creepage distances (mm) (table 18):	5mm <i>between live parts which are separated when the contactor is in the open position</i>		
	measured creepage distances (mm) .....	7,2mm		P
	2. minimum creepage distances (mm) (table 18):	5mm <i>between live parts of different polarity</i>		
	measured creepage distances (mm) .....	7,2mm		P
	3. minimum creepage distances (mm) (table 18):	3(6)mm <i>Between live parts and exposed conductive parts</i>		

IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	measured creepage distances (mm) .....	No exposed conductive parts	N/A
	TEST SEQUENCE E 1 sample: $I_{th}=20A$ , $I_e=9A$ , AC-7b		E1
9.2.4	Mechanical properties of terminals (not apply to Al terminals or to terminals for connection of Al conductors)		
9.2.4.2	Tests of mechanical strength of terminals		
	maximum cross-sectional area of conductor ( $mm^2$ ).....	4 $mm^2$	
	diameter of thread (mm) .....	3,4mm	
	torque (Nm) .....	0,8Nm	
	5 times on 2 separate clamping units		P
9.2.4.3	Test for damage to and accidental loosening of conductors (flexing test)		
	conductor of the smallest cross-sectional area ( $mm^2$ ).....	1,5 $mm^2$	
	number of conductors of the smallest cross section .....	1	
	diameter of bushing hole (mm) .....	6,4mm	
	height between the equipment and the platen ....	260mm	
	mass at the conductor(s) (kg) .....	0,4kg	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
9.2.4.4	Pull-out test		
	force (N) .....	40N	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
9.2.4.3	conductor of the largest cross-sectional area ( $mm^2$ ).....	4 $mm^2$	
	number of conductors of the largest cross section .....	1	
	diameter of bushing hole (mm) .....	9,5mm	
	height between the equipment and the platen ....	279mm	
	mass at the conductor(s) (kg) .....	0,9kg	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
9.2.4.4	Pull-out test		
	force (N) .....	60N	

IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
9.2.4.3	conductor of the largest and smallest cross-sectional area (mm <sup>2</sup> ) .....	4 mm <sup>2</sup> / 1,5 mm <sup>2</sup>	
	number of conductors of the smallest cross section, number of conductors of the largest cross section .....	1/1	
	diameter of bushing hole (mm) .....	9,5mm / 6,4mm	
	height between the equipment and the platen .....	279mm / 260mm	
	mass at the conductor(s) (kg) .....	0,9kg / 0,4kg	
	135 continuous revolutions: the conductor shall neither slip out of the terminal nor break near the clamping unit		P
9.2.4.4	Pull-out test		
	force (N) .....	60N / 40N	
	1 min, the conductor shall neither slip out of the terminal nor break near the clamping unit		P
9.2.4.5	Test for insertability of unprepared round copper conductors having the maximum specified cross-section		
	form and marking of gauge (table 13).....	A3	P
9.2.2	Test on screws or nuts other than those on terminals which are intended to be operated during installation or maintenance		
	Torque test:		
	- 10 times for thread of insulating material		N/A
	- 5 times for other		P
	- diameter (mm); torque (Nm) .....	3,4mm / 0,8Nm	P
	- diameter (mm); torque (Nm) .....		N/A
	- diameter (mm); torque (Nm) .....		N/A
	- diameter (mm); torque (Nm) .....		N/A
9.2.1.3	Resistance to heat		
	Test on contactor		
	a) ball pressure test: test temperature 125°C for 1 h; diameter of impression ≤ 2 mm (mm) .....	1,2mm <i>Enclosure and the frame of coil</i>	P
	b) ball pressure test: test temperature °C for 1 h; diameter of impression ≤ 2 mm (mm) .....		N/A
	c) test temperature 100°C to reach thermal equilibrium (not less than 1 h):		P
	- no damage, no live parts accessible (test finger 5 N)		P
	- marking still legible		P

IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	Tests on materials (material of at least 2 mm)		
	a) ball pressure test: test temperature 125°C for 1 h; diameter of impression $\leq 2$ mm (mm).....:	1,2mm <i>movable contactor block</i>	P
	b) ball pressure test: test temperature °C for 1 h; diameter of impression $\leq 2$ mm (mm).....:		N/A
9.2.1.4	Resistance to abnormal heat and fire		
	Test on parts of the contactors		
	Glow-wire test at (850 °C):	850°C <i>Enclosure and the frame of coil</i>	P
	No visible flames and no sustained glowing, or if flame and glowing, extinguish within 30 s .....	No visible flames	P
	No ignition of the tissue paper or scorching of the board		P
	Glow-wire test at (650 °C):	650°C <i>the red indicator</i>	P
	No visible flames and no sustained glowing, or if flame and glowing, extinguish within 30 s .....	No visible flames	P
	No ignition of the tissue paper or scorching of the board		P
	Tests on materials		
	a) flammability classification test, in accordance with IEC 60707	850°C <i>movable contactor block</i>	P
	b) hot wire ignition (HWI) test, as described in annex G		N/A
9.2.1.6	Resistance to tracking		
	50 drop, solution A, test voltage (V) .....	225V	P
	No flashover or breakdown		P



	TEST SEQUENCE F		
	1 sample: $I_{th} = 20A$ , $I_e = 9A$ , AC-7b	F1	
9.2.1.1	Resistance to ageing		
	resistance to ageing at temperature 70 °C for 7 days (168 h)	70 °C for 7 days	P
	After the test, no crack visible, and no traces of cloth and not stick to the cloth		P
9.2.3	Degrees of protection		
	Test procedure is under consideration	IP20 <i>to front parts</i>	P

IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	TEST SEQUENCE G 4 samples: $I_{th}=20A$ , $I_e=9A$ , AC-7b	G1	
9.3.4	Performance under short-circuit conditions		
	Conditional short-circuit current		
	type of SCPD .....	CBO: NB1-63	
	ratings of SCPD .....	230/400V, C32, $I_{cs}=I_{cn}=6000A$	
9.3.4.2.1	prospective current $I_r$ (kA) .....	3kA	
	test voltage (V) .....	L1: 262V L2: 262V L3: -	
	r.m.s. test current (A) .....	L1: 3040A L2: 3040A L3: -	
	power factor .....	0,87	
	1) one breaking operation of the SCPD shall be performed with SCPD and the contactor closed prior to the test		P
	2) one breaking operation of the SCPD shall be performed by closing the contactor on to the short-circuit		P
9.3.4.2.2	rated conditional short-circuit $I_q$ (kA) .....	6kA	
	test voltage (V) .....	L1: 262V L2: 262V L3: -	P
	r.m.s. test current (A) .....	L1: 6080A L2: 6080A L3: -	P
	power factor .....	0,65	
	1) one breaking operation of the SCPD shall be performed with SCPD and the contactor closed prior to the test		P
	2) one breaking operation of the SCPD shall be performed by closing the contactor on to the short-circuit		P
	Result to be obtained:		
	A Fault current successfully interrupted by SCPD; fuse or solid connection between the enclosure and supply not melted		P
	B Door or cover of the enclosure not blown open and it is possible to open door or cover		P





IEC 61095			
Cl.	Requirement – Test	Result	Verdict
	C No damage to the conductor or terminals ; no conductor separated from the terminals		P
	D No cracking or breaking of insulating base		P
	E No discharge of parts beyond the enclosure		P

Photos of sample:



IEC 61095

Photos of sample:





TRF No.: IEC61095A

TRF originator: EZU

IEC 61095



Photos of sample:



TRF No.: IEC61095A

TRF originator: EZU

Photos of sample:



TRF No.: IEC61095A

TRF originator: EZU