

CERTIFICATE

Issued to:
Applicant:
Zhejiang CHINT Electric Co., Ltd.
No.1, Chint Road, CHINT Industrial Zone, North
Baixiang, Yueqing, Zhejiang Province,
P.R.CHINA

Manufacturer/Licensee:
Zhejiang CHINT Electric Co., Ltd.
No.1, Chint Road, CHINT Industrial Zone, North
Baixiang, Yueqing, Zhejiang Province,
P.R.CHINA

Product(s) : Thermal overload relay
Trade name(s) : CHINT
Type(s)/model(s) : NR2-11,5

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-4-1:2010 + A1:2012; EN 60947-5-1:2004 + A1:2009; IEC 60947-4-1:2009 + A1:2012; IEC 60947-5-1:2003 + A1:2009;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2032236

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 18 September 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 3308249.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



F.S. Strikwerda
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT
Product data

product	:	Thermal overload relay
trade name(s)	:	CHINT
type(s)	:	NR2-11,5
General	:	
method of operation	:	Bimetal heated
pollution degree	:	3
main circuit	:	
number of poles	:	3
rated frequency	:	50/60 Hz
conventional thermal current (I _{th})	:	13 A
rated operational voltage (U _e)	:	380/400/415/660 Vac
rated operational current I _e (A)	:	0,1-0,16 A, 0,16-0,25 A, 0,25-0,4 A, 0,4-0,63 A, 0,63-1 A, 1-1,6 A, 1,25-2 A, 1,6-2,5 A, 2,5-4 A, 4-6 A, 5,5-8 A, 7-10 A, 9-13 A
rated insulation voltage (U _i)	:	690 V
rated impulse withstand voltage (U _{imp})	:	6 kV
rated conditional short-circuit current ("r")	:	1 kA
rated conditional short-circuit current ("I _q ")	:	50 kA
type of co-ordination	:	1
SCPD	:	fuse RT36-00(NT00), gG 20 A, 50 kA at 690 Vac
Terminal	:	Flexible and rigid stranded wire: 0,5 mm ² - 2,5 mm ²
Terminations	:	one side, screw terminals, one conductor per terminal other side, pins to be connected to contactors
auxiliary circuit	:	
number and kind of contact elements	:	1 NO and 1 NC
rated frequency	:	50/60 Hz
utilization category	:	AC-15, DC-13
conventional thermal current (I _{th})	:	5 A
rated current (I _e)	:	AC-15: 1,58 A, 380 Vac; 2,73 A, 220 Vac DC-13: 0,2 A, 220 Vdc
rated conditional short-circuit current	:	1 kA with fuse RT36-00 (NT00 gG 6 A 120 kA at 500 Vac)

TESTS**Test requirements**

EN 60947-4-1:2010 + A1:2012
EN 60947-5-1:2004 + A1:2009
IEC 60947-4-1:2009 + A1:2012
IEC 60947-5-1:2003 + A1:2009

Test result

The test results are laid down in DEKRA test file 3308249.01 and test reports No. 3308249.50 and 3301041.57.

Remarks

This certificate replaces the KEMA-KEUR certificate no. 2138222.01 issued on 2010-09-22.

Conclusion

The examination proved that all test requirements were met.

Tested by : Max Ma



Checked by : Eric Wang

**Factory locations**

Zhejiang CHINT Electrics Co., Ltd.

No.1, Chint Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.CHINA