

CERTIFICATE

Issued to:
Applicant:
Zhejiang CHINT Electric Co., Ltd.
No.1, Chint Road, CHINT Industrial Zone, North
Baixiang, Yueqing, Zhejiang Province,
P.R.CHINA

Manufacturer/Licensee:
Zhejiang CHINT Electric Co., Ltd.
No.1, Chint Road, CHINT Industrial Zone, North
Baixiang, Yueqing, Zhejiang Province,
P.R.CHINA

Product(s) : Thermal overload relay
Trade name(s) : CHINT
Type(s)/model(s) : NR2-200

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-4-1: 2010 + A1: 2012; EN 60947-5-1: 2004 + A1: 2009; IEC 60947-4-1: 2009 + A1: 2012; IEC 60947-5-1: 2003 + A1: 2009;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2032236

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.


This certificate is issued on: 21 October 2015 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 3308254.01

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



F.S. Strikwerda
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	: Thermal overload relay
trade name(s)	: CHINT
type(s)	: NR2-200
General	:
method of operation	: Bimetal heated
pollution degree	: 3
main circuit	:
number of poles	: 3
rated frequency	: 50/60 Hz
conventional thermal current (I _{th})	: 200 A
rated operational voltage (U _e)	: 380/400/415 Vac, 660 Vac
rated operational current I _e (A)	: 80-125 A, 100-160 A, 125-200 A
rated insulation voltage (U _i)	: 690 V
rated impulse withstand voltage (U _{imp})	: 6 kV
rated conditional short-circuit current ("r")	: 10 kA
rated conditional short-circuit current ("I _q ")	: 50 kA
type of co-ordination	: 1
SCPD	: fuse RT36-3(NT3), gG 315 A, 50 kA at 690 Vac
Terminal	: Prepared conductors (cables with lug): 10 mm ² - 95 mm ²
auxiliary circuit	:
number and kind of contact elements	: 1 NO and 1 NC
rated frequency	: 50/60 Hz
utilization category	: AC-15, DC-13
conventional thermal current (I _{th})	: 5 A
rated current (I _e)	: AC-15: 1,58 A, 380 Vac; 2,73 A, 220 Vac DC-13: 0,2 A, 220 Vdc
rated conditional short-circuit current	: 1 kA with fuse RT36-00 (NT00 gG 6 A 120 kA at 500 Vac)

TESTS**Test requirements**

EN 60947-4-1: 2010 + A1: 2012
EN 60947-5-1: 2004 + A1: 2009
IEC 60947-4-1: 2009 + A1: 2012
IEC 60947-5-1: 2003 + A1: 2009

Test result

The test results are laid down in DEKRA test file 3308254.01 and test reports No. 3308254.50 and 3301041.57.

Remarks

This certificate replaces the KEMA-KEUR certificate no. 2138222.01 issued on 2010-09-22.

Conclusion

The examination proved that all test requirements were met.

Tested by : Max Ma



Checked by : Eric Wang

**Factory locations**

Zhejiang CHINT Electric Co., Ltd.
No.1, Chint Road, CHINT Industrial Zone, North Baixiang, Yueqing, Zhejiang Province, P.R.CHINA