



Product Service

Attestation of Conformity

No. N8 12 11 73900 018

Holder of Certificate: Zhejiang Chint Electrics Co., Ltd.

No.1, Chint Road, Chint Industrial Zone
North Baixiang
325603 Yueqing, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

**Product: Surge protection equipment
(Surge protective Device)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 682301210401A



Date, 2012-11-20


(Alex Kong)

CE After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



Product Service

Attestation of Conformity
No. N8 12 11 73900 018

Model(s): NU6-II/W 100/385F, NU6-II/W 100/260 NPE

Trade name: CHINT

Parameters:

Mounting Method:	Fixed
Location :	Indoor
Number of Ports :	One
SPD Class :	Type 2
Max Continuous Operating Voltage Uc :	Uc: 385Vac (For NU6-II/W 100/385F) Uc: 260Vac (For NU6-II/W 100/260 NPE)
Nominal Discharge Current In :	40kA
Max Discharge Current Imax :	100kA
Voltage Protection Level Up :	Up: 1800V (For NU6-II/W 100/385F) Up: 1500V (For NU6-II/W 100/260 NPE)

Remaks :
- The maximum operating temperature is 70°C.
- Clearance was evaluated for operating altitude up to 4000m above sea level.

Tested according to: EN 61643-11/A11:2007